APPLICATION / STRUCTR	PROPERTY ADDRESS / PERMIT	County Parcel Number / INSPECTION	Old Account Number / RESULT DATE/STATUS	INSPECTOR
15 00000625	219 N ANN ST APT 101	17-117-00-02-010.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0010 EROSION CONTROL	8/19/15 DISAPPROVED	DWH
	RES COMM: Failure to stablize yard west of 219 & 223. Failure to provide engineered plans and third party varification for retaining wall south of 219. Retaining wall failure north of unit 223 and east of 221. Erosion and undermining of trees north of unit 221. Need to remove dirt berm south end of sidewalk along Ann Street, Remove dumpster from ROW. Clean out drain pipe at SW corner of property. Remove pallets and dirt from street.			
15 00000626	219 N ANN ST APT 102	17-117-00-02-010.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0008 EROSION CONTROL	8/19/15 DISAPPROVED	DWH
	RES COMM: Failure to stablize yard west of 219 & 223. Failure to provide engineered plans and third party varification for retaining wall south of 219. Retaining wall failure north of unit 223 and east of 221. Erosion and undermining of trees north of unit 221. Need to remove dirt berm south end of sidewalk along Ann Street, Remove dumpster from ROW. Clean out drain pipe at SW corner of property. Remove pallets and dirt from street.			
15 00000629	223 N ANN ST APT 101	17-117-00-02-009.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0009 EROSION CONTROL	8/19/15 DISAPPROVED	DWH
	RES COMM: Failure to stablize yard west of 219 & 223. Failure to provide engineered plans and third party varification for retaining wall south of 219. Retaining wall failure north of unit 223 and east of 221. Erosion and undermining of trees north of unit 221. Need to remove dirt berm south end of sidewalk along Ann Street, Remove dumpster from ROW. Clean out drain pipe at SW corner of property. Remove pallets and dirt from street.			
15 00000630	223 N ANN ST APT 102	17-117-00-02-009.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0010 EROSION CONTROL	8/19/15 DISAPPROVED	DWH
	RES COMM: Failure to stablize yard west of 219 & 223. Failure to provide engineered plans and third party varification for retaining wall south of 219. Retaining wall failure north of unit 223 and east of 221. Erosion and undermining of trees north of unit 221. Need to remove dirt berm south end of sidewalk along Ann Street, Remove dumpster from ROW. Clean out drain pipe at SW corner of property. Remove pallets and dirt from street.			
15 00000734	5008 FORSYTHIA FALLS LOOP	16-803-00-04-032.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0006 EROSION CONTROL	8/03/15 DISAPPROVED	HHH
	RES COMM: was grading yard out			

APPLICATION STRUCTR	PROPERTY ADDRESS PERMIT	County Parcel Number INSPECTION	Old Account Number RESULT DATE/STATUS	INSPECTOR
15 00000934	4403 CANYATA CT	16-700-00-00-003.02-01		
000 000	ERO 00 EROSION CONTROL	ER10 0005 EROSION CONTROL	8/28/15 DISAPPROVED	HHH
	RES COMM: need erosion control in rear of lot			
15 00001047	123 W ASH ST	16-319-00-09-018.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0007 EROSION CONTROL	8/19/15 DISAPPROVED	DWH
	RES COMM: Failure to stablize yard; sediment displacement onto			
	RES COMM: property west of units and in city ROW alond, Ash Street.			
15 00001048	125 W ASH ST	16-319-00-09-018.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0007 EROSION CONTROL	8/19/15 DISAPPROVED	DWH
	RES COMM: Failure to stablize yard; sediment displacement onto			
	RES COMM: property west of units and in city ROW alond, Ash Street.			
15 00001049	127 W ASH ST	16-319-00-09-018.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0008 EROSION CONTROL	8/19/15 DISAPPROVED	DWH
	RES COMM: Failure to stablize yard; sediment displacement onto			
	RES COMM: property west of units and in city ROW alond, Ash Street.			
15 00001050	129 W ASH ST	16-319-00-09-018.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0009 EROSION CONTROL	8/19/15 DISAPPROVED	DWH
	RES COMM: Failure to stablize yard; sediment displacement onto			
	RES COMM: property west of units and in city ROW alond, Ash Street.			
15 00001172	4903 FORSYTHIA FALLS LOOP	16-803-00-04-086.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0008 EROSION CONTROL	8/24/15 DISAPPROVED	HHH
	RES COMM: need erosion control replaced at SE rear corner			
15 00001362	1407 RICHARDSON ST APT 103	17-117-00-07-058.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0007 EROSION CONTROL	8/04/15 DISAPPROVED	DWH
	RES COMM: Failure to provide scurbs per plot plan.			
15 00001363	1407 RICHARDSON ST APT 104	17-117-00-07-058.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0007 EROSION CONTROL	8/04/15 DISAPPROVED	DWH
	RES COMM: Failure to provide scurbs per plot plan.			
15 00001437	4104 STEINBROOKE TER	20-200-00-08-093.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0009 EROSION CONTROL	8/24/15 DISAPPROVED	HHH
	RES COMM: ground cover needed at rear of lot			
15 00001534	4409 CANYATA CT	16-700-00-00-003.02-01		
000 000	ERO 00 EROSION CONTROL	ER10 0007 EROSION CONTROL	8/24/15 DISAPPROVED	HHH
	RES COMM: grading yard, no correction notice left			

APPLICATION / STRUCTR	PROPERTY ADDRESS / PERMIT	County Parcel Number / INSPECTION	Old Account Number / RESULT DATE/STATUS	INSPECTOR
15 00001597	3802 STEINBROOKE TER	20-200-00-08-112.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0005 EROSION CONTROL	8/27/15 DISAPPROVED	HHH
	RES COMM: clean out area inlet in back yard and protectt from erosion			
	RES COMM: control measures			
15 00001641	3807 ASTORIA WAY	20-200-00-08-034.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0008 EROSION CONTROL	8/24/15 DISAPPROVED	HHH
	RES COMM: need erosion control repaired at NE rear corner. beginning			
	RES COMM: grading			
15 00001727	608 WOLF TRL	17-204-00-01-091.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0004 EROSION CONTROL	8/05/15 DISAPPROVED	SCA
	RES COMM: 1. Maintain erosion Controls			
000 000	ERO 00 EROSION CONTROL	ER10 0006 EROSION CONTROL	8/24/15 DISAPPROVED	CAL
	RES COMM: 1. Response to citizen complaint.			
	RES COMM: 2. Silt is escaping into street from under silt fence at			
	RES COMM: left front corner of lot.			
	RES COMM: 3. Repair/maintain silt fence and clean silt from street.			
	RES COMM: 4. Remove silt from street at adjoining lot, 700 Wolf			
	RES COMM: Trail.			
15 00001731	6412 DAYCREW LOOP	20-313-00-03-004.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0002 EROSION CONTROL	8/21/15 DISAPPROVED	CKF
	RES COMM: Mud and roots not allowed in footing.			
	RES COMM: No ground work or lateral observed.			
15 00001737	6408 DAYCREW LOOP	20-313-00-03-003.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0004 EROSION CONTROL	8/25/15 DISAPPROVED	SCA
	RES COMM: 1. Footing full of mud and muck. Dig out footings again			
15 00002044	4308 PEREGRINE PL	- - - - . -		
000 000	ERO 00 EROSION CONTROL	ER10 0003 EROSION CONTROL	8/19/15 DISAPPROVED	CAL
	RES COMM: 1. Install silt fence at rear of lot.			
15 00002075	713 ANACONDA CT	11-903-00-01-064.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0004 EROSION CONTROL	8/31/15 DISAPPROVED	CAL
	RES COMM: 1. See framing 8.31.15.			
15 00002179	2010 W SOUTHAMPTON DR APT 101	16-800-00-00-006.03-01		
000 000	ERO 00 EROSION CONTROL	ER10 0001 EROSION CONTROL	8/11/15 DISAPPROVED	SCA
	RES COMM: 1. Nothing built had questions about duplex party walls.			
	RES COMM: Gave him a synopsis of code requirements. When framing			
	RES COMM: commences call for a reinspect if they still have			
	RES COMM: questions.			

APPLICATION / STRUCTR	PROPERTY ADDRESS / PERMIT	County Parcel Number / INSPECTION	Old Account Number / RESULT DATE/STATUS	INSPECTOR
15 00002311	3702 MAMBA DR	11-904-00-08-551.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0002 EROSION CONTROL	8/28/15 DISAPPROVED	CAL
	RES COMM: 1. Install silt fence along rear of lot.			
15 00002714	1006 MADISON ST	16-314-00-01-025.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0001 EROSION CONTROL	8/19/15 DISAPPROVED	SCA
	RES COMM: 1. 23' from north 19' 6" from south frontage.			
15 00002935	4205 STEINBROOKE TER	20-200-00-08-122.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0001 EROSION CONTROL	8/21/15 DISAPPROVED	DSV
	RES COMM: not ready			

RPT TOTAL: 27