APPLICATION / STRUCTR	PROPERTY ADDRESS / PERMIT	County Parcel Number / INSPECTION	Old Account Number / RESULT DATE/STATUS	INSPECTOR
14 00000483	4908 STEEPLECHASE DR	20-100-00-01-237.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0010 EROSION CONTROL	9/16/15 DISAPPROVED	HHH
		RES COMM: grading yard, no erosion control		
000 000	ERO 00 EROSION CONTROL	ER10 0011 EROSION CONTROL	9/22/15 DISAPPROVED	CKF
		RES COMM: 1.No address on building.		
		RES COMM: 2.Garage electrical panel not complete.		
		RES COMM: 3.No energy efficiency statement posted.		
		RES COMM: 4.Outside garage soffit incomplete.		
		RES COMM: 5.Exterior penatrations not sealed.		
		RES COMM: 6.Need GFCI outlets in unfinnished area of basement.		
		RES COMM: 7.Window casements not sealed.		
		RES COMM: 8.Exhaust vents not terminated properly.		
		RES COMM: 9.A.C. exterior dissconnects all wrong.		
15 00001801	2009 AUGUST BRIGGS DR	17-504-00-01-098.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0010 EROSION CONTROL	9/10/15 DISAPPROVED	CAL
		RES COMM: 1. Not ready.		
15 00001927	600 BEAR VALLEY CT	- - - - . -		
000 000	ERO 00 EROSION CONTROL	ER10 0001 EROSION CONTROL	9/17/15 DISAPPROVED	CAL
		RES COMM: 1. Need silt fence installed at back of lot.		
15 00002038	1913 LASSO CIR	17-600-00-01-320.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0006 EROSION CONTROL	9/02/15 DISAPPROVED	DWH
		RES COMM: Need to clean street.		
000 000	ERO 00 EROSION CONTROL	ER10 0008 EROSION CONTROL	9/08/15 DISAPPROVED	DWH
		RES COMM: Not ready, still working on building forms; directed to		
		RES COMM: reschedule.		
15 00002044	4308 PEREGRINE PL	- - - - . -		
000 000	ERO 00 EROSION CONTROL	ER10 0004 EROSION CONTROL	9/03/15 DISAPPROVED	DWH
		RES COMM: Rock & dirt in streets; needs to remove gravel from		
		RES COMM: cul-de-sac. Also noted on that an inspector require silt		
		RES COMM: fence be placed at the rear of lot on 8/19; silt fence not		
		RES COMM: in place as of 9/3.		
15 00002048	4310 PEREGRINE PL	- - - - . -		
000 000	ERO 00 EROSION CONTROL	ER10 0004 EROSION CONTROL	9/03/15 DISAPPROVED	DWH
		RES COMM: Rock & dirt in streets; needs to remove gravel from		
		RES COMM: cul-de-sac. Also noted on that an inspector require silt		
		RES COMM: fence be placed at the rear of lot on 8/19; silt fence not		
		RES COMM: in place as of 9/3.		
15 00002319	5422 STEEPLECHASE DR	20-100-00-02-075.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0003 EROSION CONTROL	9/18/15 DISAPPROVED	CAL

APPLICATION / STRUCTR	PROPERTY ADDRESS / PERMIT	County Parcel Number / INSPECTION	Old Account Number / RESULT DATE/STATUS	INSPECTOR
15 00002319	CONTINUED			
		RES COMM: 1. Install silt fence at rear of lot to control run-off		
		RES COMM: into creek.		
15 00002371	4408 CANYATA CT	16-700-00-00-003.02-01		
000 000	ERO 00 EROSION CONTROL	ER10 0004 EROSION CONTROL	9/18/15 DISAPPROVED	CAL
		RES COMM: 1. Control silt erosion at eroded cuts or gaps in berm at		
		RES COMM: rear of lot.		
000 000	ERO 00 EROSION CONTROL	ER10 0005 EROSION CONTROL	9/28/15 DISAPPROVED	HHH
		RES COMM: no erosion control in rear or East side yard		
15 00002730	3301 TIMBER RUN DR	20-200-00-00-015.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0006 EROSION CONTROL	9/29/15 DISAPPROVED	HHH
		RES COMM: no erosion on rear down hill side		
15 00002731	3211 TIMBER RUN DR	20-200-00-00-015.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0005 EROSION CONTROL	9/30/15 DISAPPROVED	HHH
		RES COMM: no erosion control up		
15 00002732	3209 TIMBER RUN DR	20-200-00-00-015.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0005 EROSION CONTROL	9/29/15 DISAPPROVED	HHH
		RES COMM: no erosion control in rear ditch to low point		
15 00002935	4205 STEINBROOKE TER	20-200-00-08-122.00-01		
000 000	ERO 00 EROSION CONTROL	ER10 0004 EROSION CONTROL	9/29/15 DISAPPROVED	HHH
		RES COMM: no erosion control installed		

RPT TOTAL: 15