



Downtown Leadership Council
Water & Electric Infrastructure



Water System

Total Production Capacity = 32 MGD

Total System Average = 14 MGD


Total System Peak = 26 MGD


Reserve Capacity = 6 MGD

Current Demand Downtown = 3 MGD

Net Import Capability = 12 MGD

Spare Water Capacity = 9 MGD





Electric System

Generation System

- Generation resources to balance load, MISO regulations

Transmission System: 161 kV Lines

- Power import lines, FERC, NERC, regulations for transmission

Sub-Transmission System: 69 kV Lines


- Operates under regulations for transmission, connection for other utilities
 - City of Fulton & University of Missouri

Distribution System: 13.8 kV Lines


- Substation transformers
- Community distribution feeder lines

LEGEND

- PROPOSED 161 KV LINE
- 69 KV LINE
- 161 KV LINE
- CITY LIMITS
- ELECTRIC SERVICE BOUNDARY



Electric System Current Transmission System



Electric System

Current Conditions

Load = 62 MW

Available Capacity (N-0) = 72 MW


Spare Capacity (N-0) = 10 MW

Loss of Feeder (N-1) = 9 MW

Spare Capacity (N-1) = 1 MW

Loss of Transformer (N-1) = 6 MW

Spare Capacity (N-1) = 4 MW



Electric System

New Downtown Load (+5 MW)

Load = 67 MW

Available Capacity (N-0) = 72 MW

Spare Capacity (N-0) = 5 MW

Loss of Feeder (N-1) = 9 MW

Spare Capacity (N-1) = -4 MW

Loss of Transformer (N-1) = 6 MW

Spare Capacity (N-1) = -1 MW



Electric System

Rebel Hill Addition (+5 MW):

Load = 67 MW

Available Capacity (N-0) = 77 MW


Spare Capacity (N-0) = 10 MW

Loss of Feeder (N-1) = 9 MW

Spare Capacity (N-1) = 1 MW

Loss of Transformer (N-1) = 10 MW


Spare Capacity (N-1) = 0 MW





Electric System

Impacts of New Substation





Electric System

Hinkson Creek Addition (+14 MW):

Load = 67 MW

Available Capacity (N-0) = 91 MW


Spare Capacity (N-0) = 24 MW

Loss of Feeder (N-1) = 9 MW

Spare Capacity (N-1) = 15 MW

Loss of Transformer (N-1) = 10 MW

Spare Capacity (N-1) = 14 MW



Estimated Impacts of Energy Efficiency on Load Forecasts



- Projected Residential Program Potential
 - Using Existing Programs Cost \$1.1M
 - Capacity .56 MW
- Projected Commercial Program Potential
 - Cost \$4.5M
 - Capacity 5.4 MW
- Projected Photovoltaic Potential
 - Current Rebate Cost \$1M
 - Capacity 2 MW
 - Approximately 20-25% Peak Contribution

Electric & Water Infrastructure



What Future Should Utilities Plan For?