

# Facility: Bear Creek Park

Address: 1402 Elleta Blvd.

Date of Survey: 05/25/10



## 1 ACCESS TO THE SITE AND/OR FACILITY

### 1.1 Exterior Accessible Route (sidewalks, paths, etc.)

- Refer to site plan included with this report: (B) Install a 4' wide concrete path from the shelter over to the playground areas (swings and play structures) and (C) Install 4' wide concrete path from shelter over to the basketball court (existing grade between shelter and court surface is steep and installation of a path with maximum slope of 5% will likely be infeasible, but use of some switchback sections of sidewalk will help reduce steep slopes up to the court, but will require a longer path overall): **Estimated Cost: \$5,568.00**

### 1.2 Parking

- The existing parking lot (marked "A" on site plan) has a capacity of less than 25 parking spaces (see photo 1 next page). Therefore, only 1 ADA parking space is required and it must be a van accessible space (8' wide min. with 8' wide min. access aisle). Stripe for new accessible parking space and add van access signage. **Estimated Cost: \$226.00**



Photo 1

### **1.3 Curb Cuts & Curb Ramps**

- None exist.

### **1.4 Exterior Ramps**

- None exist.

### **1.5 Exterior Stairs**

- None exist.

## **2 SERVICES**

### **2.1 Building Entrances (exterior doors)**

- Not applicable.

### **2.2 Interior Accessible Route**

- Not applicable.

### **2.3 Interior Ramps**

- Not applicable.

### **2.4 Interior Stairs**

- Not applicable.

### **2.5 Elevators**

- Not applicable.

## **2.6 Platform (wheelchair) Lifts**

- None exist.

## **2.7 Doors (interior, excluding restroom doors addressed in 3.1 and non-public area doors)**

- Not applicable.

## **2.8 Places of Assembly (auditoriums, meeting rooms, gymnasiums, etc.)**

- Not applicable.

## **2.9 Seating and Tables**

- No work.

## **2.10 Restaurant (including dining areas, snack bars & public use kitchens)**

- Not applicable.

## **2.11 NOT USED**

## **2.12 Business and Mercantile**

- Not applicable.

## **2.13 Dressing and Fitting Rooms**

- Not applicable.

## **2.14 NOT USED**

## **2.15 NOT USED**

## **2.16 Libraries**

- Not applicable.

## **2.17 Storage**

- Not applicable.

# **3 ACCESS TO PUBLIC AMENITIES**

## **3.1 Drinking Fountains**

- None exist.

### 3.2 Restrooms

- None exist.

### 3.3 Signage

- Not applicable.

### 3.4 Bathtub & Showers (including locker rooms and dressing rooms)

- Not applicable.

## 4 BARRIER REMOVAL - OTHER

### 4.1 Alarms

- Not applicable.

### 4.2 Public Telephones

- None exist.

### 4.3 Protruding Objects

- None exist.

### 4.4 Playgrounds

- Existing playground surface is pea gravel which is not wheelchair accessible. Remove pea gravel surface and install 6" – 12" thick compacted wood fiber surface at playground (~ 1,828 s.f. of playground area):

**Estimated Cost: \$4,570.00**

### 4.5 Sinks, Other than Lavatories

- Not applicable.

## 5 COST ESTIMATE

### 5.1 Cost Estimate & Notes

- Total facility cost estimate for recommended ADA modifications: **\$10,364.00**

|                  |      |                              |
|------------------|------|------------------------------|
| FACILITY SUMMARY |      | NAME: <i>Bear Creek Park</i> |
| SECTION HEADING  | COST | COMMENTS                     |

**1 Access to the Facility**

- 1.1 Exterior Accessible Route
- 1.2 Parking
- 1.3 Curb Ramps
- 1.4 Exterior Ramps
- 1.5 Exterior Stairs

|          |
|----------|
| 5,568.00 |
| 226.00   |
| -        |
| -        |
| -        |

|  |
|--|
| <i>Conc. Access paths to various areas</i>   |
| <i>Mark one van access space and signage</i> |
|  |
|  |
|  |

**2 Services**

- 2.1 Building Entrances
- 2.2 Interior Accessible Route
- 2.3 Interior Ramps
- 2.4 Interior Stairs
- 2.5 Elevators
- 2.6 Platform Lifts
- 2.7 Doors
- 2.8 Places of Assembly
- 2.9 Seating and Tables
- 2.10 Restaurant
- 2.11 NOT USED
- 2.12 Business and Mercantile
- 2.13 Dressing and Fitting Rooms
- 2.14 NOT USED
- 2.15 NOT USED
- 2.16 Libraries
- 2.17 Storage

|   |
|---|
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |
| - |

|  |
|--|
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |

**3 Access to Public Amenities**

- 3.1 Drinking Fountains
- 3.2 Toilet Rooms
- 3.3 Signage
- 3.4 Bathtubs and Showers

|   |
|---|
| - |
| - |
| - |
| - |

|  |
|--|
|  |
|  |
|  |
|  |

**4 Barrier Removal - Other**

- 4.1 Alarms
- 4.2 Public Telephones
- 4.3 Protruding Objects
- 4.4 ~~Work Areas~~ *Playgrounds*
- 4.5 Sinks, Other than Lavatories

|          |
|----------|
| -        |
| -        |
| -        |
| 4,570.00 |
| -        |

|   |
|---|
|   |
|   |
|   |
| <i>Install access surface of wood fiber over gravel</i> |
|   |

**Total Barrier Removal Cost**

|           |
|-----------|
| 10,364.00 |
|-----------|

|  |
|--|
|  |
|--|

# Bear\_Creek\_Park

1402 Elleta Boulevard



- Structure Type**
- Abandoned
  - Administrative
  - Bath House
  - Club House
  - Concession & Restroom & Locker Room (Seasonal Usage)
  - Concession & Restroom (Seasonal Usage)
  - Dug Out
  - Green House
  - Historical
  - Indoor Shelter
  - Maintenance Building
  - Maintenance Shed
  - Pump House
  - Recreation Center
  - Restroom
  - Restroom & Shelter
  - Outdoor Shelter
  - Storage
  - Un\_Designated
  - Parks and Recreation Properties



Updated: 8-31-2009 R/UEP K/V/M/C/V/G/S-Development/Park Plans



1 inch = 107.08 feet