



NOTE:

1. RAMP AND LANDING SHALL BE 6" THICK CLASS A REINFORCED CONCRETE W/#4 BARS @ 12" O.C.
2. EXPANSION JOINT SHALL BE 1/2" PREFORMED CORK OR BITUMINOUS EXPANSION JOINT MATERIAL.
3. MAXIMUM RAMP CROSS SLOPE IS 2.00%.
4. ALL SLOPES ARE MEASURED FROM THE HORIZONTAL.
5. REPLACE STANDARD CURB SECTION WITH SIDEWALK RAMP CURB SECTION - DETAIL 400.01
6. RAMP LENGTH IS DEPENDENT ON 1:12 MAX. SLOPE. USE FLATTER WHEN POSSIBLE.
7. LANDING AREA SHALL BE 4'-0" MIN WIDTH, CROSS SLOPE OF LANDING SHALL NOT EXCEED 2.00%.
8. USE TYPE "B" RAMP ONLY IF TYPE "A" IS NOT FEASIBLE.

<i>JLB</i>	1/1/12
Approved	Date
<b>Revisions</b>	



**SIDEWALK RAMP**  
Sidewalk at Back of Curb  
(Type B)

432.02