

APPLICATION PERMIT PROPERTY ADDRESS
STRUCTR PERMIT

County Parcel Number
INSPECTION

Old Account Number
RESULT DATE/STATUS

INSPECTOR

13 00000978 203 GONDOLIER DR
000 000 EROSION CONTROL

11-902-00-01-022.00-01
ER10 0007 EROSION CONTROL

9/30/13 DISAPPROVED

CAL

REQ COMM:
RES COMM: 1. GFCI-protect all recepts in unfinished basement area.
RES COMM: 2. Masterpath exhaust fan not working properly.
RES COMM: 3. Install range anti-tip device.
RES COMM: 4. Install receptacle to serve left side of sink.
RES COMM: 5. Add recept right side of range to serve c-top. No point
RES COMM: along countertop can be more than 24-inches from recept.
RES COMM: 6. Install electrical boxes behind all exterior wall-mount
RES COMM: light fixtures.
RES COMM: 7. Need lag bolts at deck ledger in each joist space.
RES COMM: 8. Secure all hose bibs.
RES COMM: 9. Maintain 6-inch clearance between pex and single-wall
RES COMM: exhaust pipe at water heater.
RES COMM: 10. Need locking caps at outdoor AC unit.
RES COMM: 11. Install silt fence at right side of lot and also at
RES COMM: rear of lot.

13 00002348 5810 MORNING STAR CT
000 000 ERO 00 EROSION CONTROL

20-100-00-00-008.01-01
ER10 0004 EROSION CONTROL

9/19/13 DISAPPROVED

CAL

RES COMM: 1. Need additional erosion measures at east side and rear
RES COMM: of lot.

13 00002407 6209 BRIDLE BEND DR
000 000 ERO 00 EROSION CONTROL

17-600-00-01-053.00-01
ER10 0007 EROSION CONTROL

9/26/13 DISAPPROVED

CAL

RES COMM: 1. Clean dirt and gravel from street and from storm drain.
RES COMM: 2. Install silt fence along west front property line and
RES COMM: again at rear west low drainage point.

13 00002634 1204 RAINBOW TROUT CIR
000 000 ERO 00 EROSION CONTROL

ER10 0003 EROSION CONTROL

9/10/13 DISAPPROVED

SCA

RES COMM: 1. Drop inlets are still not protected third notice of
RES COMM: violation.

13 00002637 1208 RAINBOW TROUT CIR
000 000 ERO 00 EROSION CONTROL

ER10 0003 EROSION CONTROL

9/10/13 DISAPPROVED

SCA

RES COMM: 1. Drop inlets are still not protected third notice of
RES COMM: violation.

13 00002795 4106 ABBINGTON TER
000 000 ERO 00 EROSION CONTROL

ER10 0005 EROSION CONTROL

9/18/13 DISAPPROVED

SCA

RES COMM: 1. Insulation not complete.

 APPLICATION PROPERTY ADDRESS County Parcel Number Old Account Number
 STRUCTR PERMIT INSPECTION RESULT DATE/STATUS INSPECTOR

13 00003170 5706 SALTON CT 20-100-00-02-057.00-01
 000 000 ERO 00 EROSION CONTROL ERI0 0002 EROSION CONTROL 9/10/13 DISAPPROVED CAL
 RES COMM: 1. Repair silt fence at rear of lot.
 RES COMM: 2. Extend silt fence along entire rear of lot.

13 00003457 1001 WESTPORT DR 16-510-00-01-018.00-01 0310905010
 000 000 ERO 00 EROSION CONTROL ERI0 0001 EROSION CONTROL 9/19/13 DISAPPROVED SCA
 RES COMM: 1. Bury bottom of silt fence properly so it can effectively
 RES COMM: prevent silt from leaving lot.

13 00003466 6404 UPPER BRIDLE BEND DR 17-600-00-01-039.00-01
 000 000 ERO 00 EROSION CONTROL ERI0 0002 EROSION CONTROL 9/17/13 DISAPPROVED CAL
 RES COMM: 1. Plmb gw not ready.
 RES COMM: 2. Need silt fence along west side of property line.