

APPLICATION STRUCTR PERMIT PROPERTY ADDRESS County Parcel Number Old Account Number INSPECTOR
 RESULT DATE/STATUS

13 00001866 1009 SYCAMORE LN 16-905-00-02-107.01-01 ERI0 0007 EROSION CONTROL 10/31/13 DISAPPROVED DRB
 RES COMM: 1-No power to jettied tub outlet, secure outlet
 RES COMM: 2-Repair silt fence

13 00001948 711 N ANN ST STE 101 17-113-00-27-011.00-01 ERI0 0007 EROSION CONTROL 10/01/13 DISAPPROVED CAL
 RES COMM: 1. Control erosion SE corner of lot.

13 00001950 711 N ANN ST STE 102 17-113-00-27-011.00-01 ERI0 0007 EROSION CONTROL 10/01/13 DISAPPROVED CAL
 RES COMM: 1. Erosion control SE corner.

13 00001951 711 N ANN ST STE 103 17-113-00-27-011.00-01 ERI0 0006 EROSION CONTROL 10/01/13 DISAPPROVED CAL
 RES COMM: 1. silt fence needed at SE corner.

13 00001952 711 N ANN ST STE 104 17-113-00-27-011.00-01 ERI0 0007 EROSION CONTROL 10/01/13 DISAPPROVED CAL
 RES COMM: 1. Install silt fence southeast corner of lot.

13 00002200 2003 SURREY CT 16-419-00-04-011.00-01 ERI0 0004 EROSION CONTROL 10/02/13 DISAPPROVED CAL
 RES COMM:
 RES COMM: 1. Install silt fence north and south sides of lot.
 RES COMM: 2. More than 10-romex cables in a romex connector exceeds
 RES COMM: max permitted.
 RES COMM: 3. Install wind uplift protection at covered deck.

13 00002535 4404 RYEFIELD CT 16-104-00-00-006.00-01 ERI0 0005 EROSION CONTROL 10/17/13 DISAPPROVED CAL
 RES COMM:
 RES COMM: Erosion control needed to prevent
 sediment running into the creek. Needs
 to be corrected as soon as possible.
 T/S: 07/19/2013 02:14 PM DMHAGENH --

13 00002593 7412 ROSEDOWN DR 16-203-00-00-009.00-01 ERI0 0010 EROSION CONTROL 10/21/13 DISAPPROVED SCA
 RES COMM: 1. Issue not addressed

13 00003568 4014 SAVOY DR 16-203-00-00-009.00-01 ERI0 0001 EROSION CONTROL 10/28/13 DISAPPROVED DRB
 RES COMM: 1. Issue not addressed

APPLICATION PROPERTY ADDRESS County Parcel Number Old Account Number
STRUCTR PERMIT INSPECTION RESULT DATE/STATUS INSPECTOR

13 00003568 CONTINUED RES COMM: 1-not ready for inspection

13 00003639 2422 BOULDER SPRINGS DR 16-604-00-02-001.00-01 10/04/13 DRB
000 000 ERO 00 EROSION CONTROL ERI0 0001 EROSION CONTROL DISAPPROVED

13 00003640 2420 BOULDER SPRINGS DR 16-604-00-02-001.00-01 10/04/13 DRB
000 000 ERO 00 EROSION CONTROL ERI0 0001 EROSION CONTROL DISAPPROVED

13 00003838 2016 DEVONSHIRE DR 16-800-00-06-031.00-01 10/24/13 SCA
000 000 ERO 00 EROSION CONTROL ERI0 0001 EROSION CONTROL DISAPPROVED

RES COMM: 1. work not done

RES COMM: 1-not ready for inspection

RES COMM: 1-not ready for inspection