

APPLICATION STRUCTR PERMIT PROPERTY ADDRESS

---

County Parcel Number Old Account Number  
INSPECTOR RESULT DATE/STATUS

13 00000918 2899 S PROVIDENCE RD 12/13/13 DISAPPROVED SCA  
000 000 EROSION CONTROL

16-907-00-21-001.00-01  
ER10 0008 EROSION CONTROL  
RES COMM: 1. Need additional addresses posted at front entrance. 2.  
RES COMM: Need Yard grade approved. 3. Need COC (rental compliance)  
RES COMM: 4. Need to label meter sockets and a/c disconnects. 5.  
RES COMM: Remove boots from smokes. 6. UF plumbing under kitchen  
RES COMM: sinks. 7. P/L valves not plumbed to approved locations. 8.  
RES COMM: Handrails need returns at stairs to lower levels. 9.  
RES COMM: Clean-out caps missing at laundry areas.

13 00000919 2895 S PROVIDENCE RD 12/13/13 DISAPPROVED SCA  
000 000 EROSION CONTROL

16-907-00-21-001.00-01  
ER10 0008 EROSION CONTROL  
RES COMM: 1. Need additional addresses posted at front entrance. 2.  
RES COMM: Need Yard grade approved. 3. Need COC (rental compliance)  
RES COMM: 4. Need to label meter sockets and a/c disconnects. 5.  
RES COMM: Remove boots from smokes. 6. UF plumbing under kitchen  
RES COMM: sinks. 7. P/L valves not plumbed to approved locations. 8.  
RES COMM: Handrails need returns at stairs to lower levels. 9.  
RES COMM: Clean-out caps missing at laundry areas.

13 00000920 2891 S PROVIDENCE RD 12/13/13 DISAPPROVED SCA  
000 000 EROSION CONTROL

16-907-00-21-001.00-01  
ER10 0008 EROSION CONTROL  
RES COMM: 1. Need additional addresses posted at front entrance. 2.  
RES COMM: Need Yard grade approved. 3. Need COC (rental compliance)  
RES COMM: 4. Need to label meter sockets and a/c disconnects. 5.  
RES COMM: Remove boots from smokes. 6. UF plumbing under kitchen  
RES COMM: sinks. 7. P/L valves not plumbed to approved locations. 8.  
RES COMM: Handrails need returns at stairs to lower levels. 9.  
RES COMM: Clean-out caps missing at laundry areas.

13 00000921 2887 S PROVIDENCE RD 12/13/13 DISAPPROVED SCA  
000 000 EROSION CONTROL

16-907-00-21-001.00-01  
ER10 0008 EROSION CONTROL  
RES COMM: 1. Need additional addresses posted at front entrance. 2.  
RES COMM: Need Yard grade approved. 3. Need COC (rental compliance)  
RES COMM: 4. Need to label meter sockets and a/c disconnects. 5.  
RES COMM: Remove boots from smokes. 6. UF plumbing under kitchen  
RES COMM: sinks. 7. P/L valves not plumbed to approved locations. 8.  
RES COMM: Handrails need returns at stairs to lower levels. 9.  
RES COMM: Clean-out caps missing at laundry areas.

13 00002221 6909 MONTAUK CT 12/18/13 DISAPPROVED HHH  
000 000 EROSION CONTROL

20-200-00-00-019.00-01  
ER10 0011 EROSION CONTROL  
RES COMM: need silt fence repaired in rear center of lot.

13 00002596 4611 COPPERSTONE CT 12/17/13 DISAPPROVED DRB  
000 000 EROSION CONTROL

16-803-00-02-024.00-01  
ER10 0009 EROSION CONTROL  
RES COMM: not ready for finals

-----  
APPLICATION PERMIT PROPERTY ADDRESS County Parcel Number Old Account Number  
STRUCTR PERMIT INSPECTION RESULT DATE/STATUS INSPECTOR  
-----

13 00002611 5708 ISLIP DR ERO 00 EROSION CONTROL ERI0 0009 EROSION CONTROL 12/10/13 DISAPPROVED CAL

RES COMM: 1. Use of plastic outlet boxes is not permitted with metal-clad (MC) cable. See Kitchen island recept.  
RES COMM: 2. At unfinished basement, complete insulation of rim joist at south wall.  
RES COMM: 3. Missing lag bolts at some deck joist bays.  
RES COMM: 4. Property attach deck hold-down tension devices to interior floor joists.  
RES COMM: 5. Inadequate grass seeding for rear and side lots.  
RES COMM: 6. Fluorescent light fixture in master closet is not permitted within 6-inches of shelf storage space.  
RES COMM: 7. Repair silt fence at southeast corner of lot.  
RES COMM: 8. Connect southeast downspout to underground drain.

13 00002784 1303 OLD HAWTHORNE DRIVE EAST ERO 00 EROSION CONTROL ERI0 0009 EROSION CONTROL 12/30/13 DISAPPROVED DRB

RES COMM: 1-several violations, not ready for inspection

13 00003342 5201 WHITEFISH DR ERO 00 EROSION CONTROL ERI0 0004 EROSION CONTROL 12/04/13 DISAPPROVED DRB

REQ COMM:  
RES COMM: 1-Need silt fence at east side of rear yard

13 00003724 2809 PARKER ST ERO 00 EROSION CONTROL ERI0 0008 EROSION CONTROL 12/27/13 DISAPPROVED CAL

RES COMM: 1. Seal all exterior penetrations.  
RES COMM: 2. Install electrical disconnect at furnace location.  
RES COMM: 3. Cap-off or safely terminate exposed conductors at exterior AC unit.  
RES COMM: 4. Missing faceplate for microwave recept.  
RES COMM: 5. Repair and extend silt fence at north property line.

13 00003790 5610 ABERCORN DR ERO 00 EROSION CONTROL 20-200-00-08-078.00-01 ERI0 0005 EROSION CONTROL 12/19/13 DISAPPROVED DRB

RES COMM: not ready for inspection

13 00003821 3803 CLYDESDALE DR ERO 00 EROSION CONTROL ERI0 0002 EROSION CONTROL 12/02/13 DISAPPROVED CAL

RES COMM: 1. Install silt fence at rear of lot to prevent spill over retaining wall.  
RES COMM: 2. Install silt fence at north side and at northeast corner  
RES COMM: as needed to contain run-off.

13 00003903 1600 BALLENTINE LN ERO 00 EROSION CONTROL ERI0 0004 EROSION CONTROL 12/10/13 DISAPPROVED DRB

PREPARED 1/02/14, 15:38:06  
PROGRAM BP521L  
City of Columbia

INSPECTION HISTORY REPORT  
12/01/13 THRU 12/31/13

PAGE 3

APPLICATION PROPERTY ADDRESS  
STRUCTR PERMIT

County Parcel Number  
INSPECTION

Old Account Number  
RESULT DATE/STATUS

INSPECTOR

13 00003903 CONTINUED

RES COMM: 1-need silt fence at year yard

14 00000272 3903 TIMBER RUN DR  
000 000 ERO 00 EROSION CONTROL

ERI0 0005 EROSION CONTROL 12/13/13 DISAPPROVED  
RES COMM: 1. repair silt fence at northwest corner (rear, left-hand  
RES COMM: side of lot).

CAL