

APPLICATOR PROPERTY ADDRESS
 STRUCTR PERMIT

County Parcel Number
 INSPECTION

Old Account Number
 RESULT DATE/STATUS

INSPECTOR

13 00002610 6804 MONTAUK CT
 000 000 ERO 00 EROSION CONTROL

20-200-00-09-011.00-01
 ERI0 0010 EROSION CONTROL

1/03/14 DISAPPROVED

DRB

13 00002932 410 GRAPEVINE CT
 000 000 ERO 00 EROSION CONTROL

ERI0 0007 EROSION CONTROL
 RES COMM: 1. Install/extend silt fence along south side near front of lot.

1/16/14 DISAPPROVED

CAL

13 00002993 6509 CASHS CROSSING
 000 000 ERO 00 EROSION CONTROL

17-600-00-01-232.00-01
 ERI0 0004 EROSION CONTROL

1/17/14 DISAPPROVED

SCA

13 00003586 2914 SCOTT BLVD
 000 000 ERO 00 EROSION CONTROL

16-801-00-02-092.01-01
 ERI0 0003 EROSION CONTROL

1/21/14 DISAPPROVED

CKF

000 000 ERO 00 EROSION CONTROL

RES COMM: 1. Seal service raceway to prevent condensation when panel is located in conditioned space.
 RES COMM: 2. Effectively close unused opening in top wall of meter enclosure.
 RES COMM: 3. Fireblock top of concealed space located at water heater.
 RES COMM: wall/bottom of steps.
 RES COMM: 4. Need minimum headroom at upstairs toilet.
 RES COMM: 5. Install silt fence at drainage ditch between two lots.

1/27/14 DISAPPROVED

CAL

13 00003588 2912 SCOTT BLVD
 000 000 ERO 00 EROSION CONTROL

16-801-00-02-092.00-01
 ERI0 0003 EROSION CONTROL

1/21/14 DISAPPROVED

CKF

13 00003685 3104 CARMELLO ROCK DR
 000 000 ERO 00 EROSION CONTROL

ERI0 0001 EROSION CONTROL

1/30/14 DISAPPROVED

SCA

13 00004018 7001 MONTAUK CT
 000 000 ERO 00 EROSION CONTROL

20-200-00-00-019.00-01
 ERI0 0003 EROSION CONTROL

1/28/14 DISAPPROVED

CKF

RES COMM: Need to have silt fencing put up at the rear and side yards
 RES COMM: Contractor given two days to comply.

PREPARED 2/03/14, 13:12:51
PROGRAM BP521L
City of Columbia

INSPECTION HISTORY REPORT
1/01/14 THRU 1/31/14

PAGE 2

APPLICATION PROPERTY ADDRESS County Parcel Number Old Account Number INSPECTOR
STRUCTR PERMIT INSPECTION RESULT DATE/STATUS -----

14 00000459 5108 HENWICH DR 20-100-00-01-518.00-01 1/16/14 DISAPPROVED CAT
000 000 ERO 00 EROSION CONTROL ERI0 0002 EROSION CONTROL RES COMM: 1. Install sill fences along rear of property and along
RES COMM: right side of lot.