

-----  
 APPLICATION STRUCTR PERMIT PROPERTY ADDRESS  
 County Parcel Number  
 INSPECTION RESULT DATE/STATUS  
 Old Account Number  
 INSPECTOR  
 -----

13 00003883 5429 STEEPLECHASE DR 20-100-00-02-087.00-01 11/07/14 DISAPPROVED HHH  
 ERO 00 EROSION CONTROL RES COMM: no erosion control on rear of bldg or east front and rear  
 RES COMM: corners

13 00003892 4501 WEYBRIDGE DR 16-104-00-02-174.00-01 11/24/14 DISAPPROVED DWH  
 ERO 00 EROSION CONTROL RES COMM: Stock piling dirt in ROW, NOV issued.  
 ERI0 0004 EROSION CONTROL

14 00000762 1704 SWIFT CT 16-415-00-03-007.00-01 11/17/14 DISAPPROVED CKF  
 ERO 00 EROSION CONTROL RES COMM: Need Access to do inspections. garage code given does not  
 RES COMM: work.  
 ERI0 0009 EROSION CONTROL

14 00001583 904 OLD HAWTHORNE DRIVE EAST 17-600-00-00-001.00-01 11/11/14 DISAPPROVED CKF  
 ERO 00 EROSION CONTROL RES COMM: Pressure less than 10psi on guage  
 ERI0 0009 EROSION CONTROL

14 00002971 5414 STEEPLECHASE DR 20-100-00-02-072.00-01 11/03/14 DISAPPROVED HHH  
 ERO 00 EROSION CONTROL RES COMM: no erosion controls in rear, using development berm that is  
 RES COMM: blown out and eroding down the hill  
 ERI0 0006 EROSION CONTROL

15 00000231 3710 FLATWATER DR 12-503-00-00-021.00-01 11/03/14 DISAPPROVED DWH  
 ERO 00 EROSION CONTROL RES COMM: Stockpiling material/dirt in ROW, no sill fence in place.  
 RES COMM: Notice of Violation to be issued to contractor/owner.  
 ERI0 0001 EROSION CONTROL

RPT TOTAL: 6