

| APPLICATION STRUCTR | PROPERTY ADDRESS PERMIT | County Parcel Number INSPECTION | Old Account Number RESULT DATE/STATUS | INSPECTOR |
|--|--|---|--|-----------|
| 14 00001918 000 000 | 310 E BRANDON RD ERO 00 EROSION CONTROL | 16-612-00-02-013.00-01 ER10 0013 EROSION CONTROL | 0820313010 6/23/16 DISAPPROVED | LNU |
| RES COMM: No erosion in yard. | | | | |
| 14 00002796 000 000 | 804 BROADHEAD ST ERO 00 EROSION CONTROL | 16-318-00-05-012.00-01 ER10 0005 EROSION CONTROL | 1940110300 6/30/16 DISAPPROVED | LNU |
| RES COMM: No prior inspection for the driveway installation, that RES COMM: doesn't meet code. No positive fall from the home RES COMM: foundation. No protection from silt leaving property at low RES COMM: points in yard. | | | | |
| 16 00000568 000 000 | 2608 SUNFLOWER ST ERO 00 EROSION CONTROL | 16-207-00-11-001.00-01 ER10 0008 EROSION CONTROL | 6/10/16 DISAPPROVED | LNU |
| RES COMM: Silt fence along Rte E is down and needs maintained. RES COMM: Additional silt fence needs installed due to areas RES COMM: distirbed. | | | | |
| 000 000 | ERO 00 EROSION CONTROL | ER10 0009 EROSION CONTROL | 6/21/16 DISAPPROVED | LNU |
| RES COMM: silt fence placed isn't embedded in ground. | | | | |
| 000 000 | ERO 00 EROSION CONTROL | ER10 0010 EROSION CONTROL | 6/23/16 DISAPPROVED | LNU |
| REQ COMM: John 999-6025 RES COMM: The silt fence isn't installed properly.Needs to be RES COMM: embedded in ground. | | | | |
| 16 00001495 000 000 | 5831 MISTY SPRINGS WAY ERO 00 EROSION CONTROL | 12-503-00-14-117.00-01 ER10 0005 EROSION CONTROL | 6/10/16 DISAPPROVED | SCA |
| REQ COMM: Bill 808-2007 RES COMM: unfortunatly i was unable to complete inspection. R105.7 RES COMM: requires permit be on site and policy requires its presence RES COMM: prior to conducting the inspection. | | | | |
| 16 00001555 000 000 | 205 WILLIAM SMITH PL ERO 00 EROSION CONTROL | 20-307-00-04-003.00-01 ER10 0004 EROSION CONTROL | 6/22/16 DISAPPROVED | HHH |
| 16 00001961 000 000 | 1205 SHALLOW RIDGE CIR ERO 00 EROSION CONTROL | 17-502-00-01-007.00-01 ER10 0002 EROSION CONTROL | 6/16/16 DISAPPROVED | SCA |
| RES COMM: 1. no permit/no Inspection. I hope I am not the only RES COMM: inspector not completing inspections for no permit. Nothing RES COMM: pleasant about it. | | | | |
| 16 00002073 000 000 | 143 DONALD NEIL CT ERO 00 EROSION CONTROL | 20-307-00-04-028.00-01 ER10 0002 EROSION CONTROL | 6/07/16 DISAPPROVED | SCA |
| RES COMM: 1. inspection not completed. no permit on site. Per JPS. | | | | |
| 16 00002347 000 000 | 901 MARCASSIN DR ERO 00 EROSION CONTROL | 17-502-00-02-103.00-01 ER10 0001 EROSION CONTROL | 6/21/16 DISAPPROVED | DRB |

| APPLICATION STRUCTR | PROPERTY ADDRESS PERMIT | County Parcel Number INSPECTION | Old Account Number RESULT DATE/STATUS | INSPECTOR |
|------------------------|---|---|--|-----------|
| 16 00002380 000 000 | 4101 GOLD STAR CT ERO 00 EROSION CONTROL | 12-804-00-03-002.00-01 ER10 0001 EROSION CONTROL | 6/21/16 DISAPPROVED | DRB |
| | | RES COMM: Need silt fence at north side, and fence at rear of lot RES COMM: needs to be properly installed | | |
| 000 000 | ERO 00 EROSION CONTROL | ER10 0002 EROSION CONTROL | 6/22/16 DISAPPROVED | DRB |
| | | RES COMM: 1-No inspection performed, need silt fence at north side of RES COMM: lot | | |

RPT TOTAL: 12