

APPLICATION STRUCTR	PROPERTY ADDRESS PERMIT	County Parcel Number INSPECTION	Old Account Number RESULT DATE/STATUS	INSPECTOR
16 00003333 000 000	5824 ABBEY LN ERO 00 EROSION CONTROL	12-503-00-14-113.00-01 ER10 0006 EROSION CONTROL	7/13/18 DISAPPROVED	CAL
		RES COMM: 1. Install or extend silt fence along left (north) side RES COMM: (north) side of lot, to prevent silt run-off into RES COMM: neighbor's yard.		
16 00003401 000 000	2804 CHINABERRY DR ERO 00 EROSION CONTROL	17-702-00-07-044.00-01 ER10 0005 EROSION CONTROL	7/23/18 DISAPPROVED	KMG
		REQ COMM: Ray 808-3860 COW REQ COMM: Mark please get with Ray and get the site worked out with REQ COMM: everything for erosion, run off, streets, and protection of REQ COMM: lake and anything else that may be suspect. Thanks DRB RES COMM: Issued NOV		
18 00000043 000 000	105 LYNN ST ERO 00 EROSION CONTROL	16-315-00-11-039.00-01 ER10 0001 EROSION CONTROL	7/06/18 DISAPPROVED	RJM
		RES COMM: Install silt fence along north end of property until grass RES COMM: is established.		
18 00000360 000 000	2303 MACE DR ERO 00 EROSION CONTROL	17-703-00-07-057.00-01 ER10 0011 EROSION CONTROL	7/26/18 DISAPPROVED	KMG
18 00001275 000 000	104 SUMMIT PEAK DR ERO 00 EROSION CONTROL	11-907-00-01-111.00-01 ER10 0006 EROSION CONTROL	7/25/18 DISAPPROVED	DRB
		RES COMM: Contrator to remove one half piece sheetrock at top of RES COMM: exterior wall in every room for insulation verification and RES COMM: at area where anchor bolts needed for failed framing RES COMM: inspection		
18 00001365 000 000	4809 STONE MOUNTAIN PKWY ERO 00 EROSION CONTROL	17-504-00-01-126.00-01 ER10 0004 EROSION CONTROL	7/20/18 DISAPPROVED	KMG
		RES COMM: no erodin control on site, issued violation		
18 00001968 000 000	625 BLACK WOLF LOOP ERO 00 EROSION CONTROL	17-502-00-06-001.00-01 ER10 0003 EROSION CONTROL	7/18/18 DISAPPROVED	CAL
		RES COMM: 1. Install silt fence/erosion control at rear of lot.		
18 00002379 000 000	2213 MACE DR ERO 00 EROSION CONTROL	17-703-00-07-055.00-01 ER10 0001 EROSION CONTROL	7/05/18 DISAPPROVED	CKF
		RES COMM: not ready		

RPT TOTAL: 8