Memorandum

To: More's Lake CCR File

From: Christian Johanningmeier, PE, Power Production Superintendent

Date: June 23, 2017

Subject: Initial Annual Inspection of CCR Surface Impoundment (40 CFR 257.100(e)(4)(iv))

40 CFR 257.100(e)(4)(iv) requires that an annual inspection of an inactive CCR impoundment must be conducted throughout its operating life. These inspections are focused primarily on the structural stability of the unit and must ensure that the operation and maintenance of the unit is in accordance with recognized and generally accepted good engineering standards. Each inspection must be conducted by a qualified professional engineer.

I conducted an inspection of More's Lake at the City of Columbia's Municipal Power Plant located at 1501 Business Loop 70 E in Columbia, MO. Details of the inspection follow:

1. More's Lake was essentially empty with the exception of about 3-4 feet of water at the bottom toward the southwest corner. The lake has been drained to dewater and recover CCRs. The lake is actively pumped after rain events to maintain a low water level. The lake was actively being pumped at the time of inspection.
2. The outlet structure was inspected and consists of an 8" diameter pipe with and elbow turned to elevation 766.50. The outlet structure was in good condition. Rip-rap stone placed around the outlet structure for protection was also in good condition. A hose from the outlet of the lake dewatering system was inserted into the lake outlet pipe and was discharging at the time of inspection.
3. The lake outfall structure was opened and inspected. The outfall is located in a manhole structure near the southwest corner of the dam near the toe. The lake outfall pipe discharges into the manhole. A separate pipe leads north from the manhole and eventually discharges downstream of the dam near I-70.
4. The top of the dam was inspected for any signs of erosion, washouts, animal burrows, vegetation, or any other anomalies. None were found. The top of the dam had a good stand of grassy vegetation that was mowed and in good condition. Rip-rap stone placed along the water side of the dam was in place and in good condition.
5. Likewise, the face and toe of the dam was inspected for any signs of erosions, washouts, animal burrows, boils, holes, or any other anomalies. None were found. The face of the dam had a good stand of grassy vegetation that was mowed and in good condition. The toe of the dam was largely covered in a gravel parking area for the City of Columbia Public Works department in the southwest quadrant and a Water & Light storage yard in the northwest quadrant.
6. The location of existing piezometers was reviewed and located in the field (refer to Crockett Dam Stability Report dated 7/25/14). All piezometers were located and inspected and found to be in good condition. Water levels were not taken.

7. Inspection of the upstream sides of the lake were also inspected. The north shore of the lake was largely covered by a large pile of CCRs that have been recovered from the lake. The condition of the south shore was similar.
8. Locations where water enters the lake where inspected and are located primarily on the east side of the lake. Three storm water pipes enter the lake as well as a temporary pipe installed by MPP personnel from the MPP deep sewer system. No issues were detected.

Christian Johanningmeier, PE – (E-026307)