



July 29, 2019

Chris Nagel
Director, Solid Waste Management Program
Missouri Department of Natural Resources
P.O. Box 176
Jefferson City, Missouri 65102

Re: Notification of Groundwater Assessment Monitoring Program - City of Columbia Water & Light Department Inactive CCR Surface Impoundment (More's Lake)

Dear Mr. Nagel:

The final rule for the regulation and management of Coal Combustion Residuals (CCR) was published by the United States Environmental Protection Agency (USEPA) in 40 CFR §257 and §261 (herein referred to as the Final Rule). The Final Rule applies to the inactive CCR surface impoundment known as More's Lake at City of Columbia Water & Light Department's (City) Columbia Municipal Power Plant (CMPP).

From recent analysis of groundwater monitoring data, a statistically significant increase over background levels has been detected at More's Lake for one or more constituents listed in Appendix III to Part 257. This letter is to notify you on behalf of the City that an assessment monitoring program has been established and will be carried out in accordance with 40 CFR §257.95.

If you have questions regarding the information presented herein please contact Brian Weis at 816-823-7824 or via email at bweis@burnsmcd.com.

Sincerely,

A handwritten signature in blue ink that reads "B. C. Weis".

Mr. Brian C. Weis, PE
Project Manager

cc: Christian Johanningmeier (City)
Darrell Hartley (MDNR)
Jeremiah Jackson (MDNR)