

## Stormwater BMP Owner Inspection Form Rain Garden City of Columbia, Missouri

Address:			
Owner:			
Legal:			
Date:	E-mail:	Phone: ()	

I. GENERAL INSPECTION RESULTS BMP's in General Inspection Results Item BMP does not appear to be well 1 Apparent problems No problems maintained. BMP observed have to 2 **Design flaws** No flaws significant design flaws which lessen its effectiveness. BMP has unauthorized Unauthorized 3  $\square$ No modifications modifications that reduce its modifications effectiveness. BMP has been destroyed or BMP removed BMP present 4 removed from property. debris Trash and has accumulated on/in BMP. Yard 5 Trash No Trash waste in BMP. Evidence of Oil, gasoline. Contaminated Uncontaminated 6  $\square$  $\square$ Contaminants or other pollutants. 7 Smells Doesn't smell Unpleasant odors from the BMP. **II. BMP SPECIFIC INSPECTION RESULTS – RAIN GARDEN** Inspection Results Item BMP : Rain Garden Sediment depth exceeds 2 inches on more than 10% of Sediment No sediment vegetated treatment area or 1 accumulated accumulated interferes with BMP performance.



## Stormwater BMP Owner Inspection Form Rain Garden City of Columbia, Missouri

2	Erosion or scouring	No erosion or scouring	Eroded or scoured areas (including spillway) due to flow channelization, higher flows, wind or water.
3	Poor vegetation	Proper vegetation	Planted vegetation is sparse or bare or eroded patches occur in more than 10% of the BMP.
4	Nuisance vegetation	Proper vegetation	Planted vegetation is excessively tall; nuisance weeds, invasive or noxious vegetation are overgrown; vegetation reduces free movement of water through BMP.
5	Brush/trees	Proper vegetation	Growth of brush and trees does not allow for proper maintenance.
6	Standing water	No standing water	Water is observed within the BMP (between storms) and appears not to drain freely or soil is excessively soggy. Excessive ponding of water within vegetated swale or other BMP.
7	Clogged	Not clogged	Inlet/outlet clogged or obstructed with sediment and/or debris.
8	Flow	No flow	Small quantities of water flow through the BMP, even when it has been dry for weeks, and an eroded, muddy channel has formed in the bottom.
9	Clogged	Not clogged	Overflow clogged or obstructed with sediment and/or debris.



## Stormwater BMP Owner Inspection Form Rain Garden City of Columbia, Missouri

1. Is maintenance needed at this time?	□ Yes	□ No			
2. Are mosquitoes or mosquito larvae present?	□ Yes	🗆 No			
3. Maintenance items needed/completed:					
· · · · · · · · · · · · · · · · · · ·					
Return completed form by either of the following:					
<ul> <li>Email – stormwaterbmp@como.gov (preferred method)</li> </ul>					
<ul> <li>Mail – City of Columbia Stormwater Utility, P.O. Box 6015, Columbia, MO 65205-6015</li> </ul>					
For guestions, call (573) 441-5530.					

Inspected by:

Signature

[Print Full Name]

FOR CITY USE ONLY - DO NOT FILL		
Date received :	Received By:	
Comments/Corrective actions required:		